



Well Report

CUSTOMER INFORMATION

REPORT #: 5078	DATE OF TEST: 9/24/12
CUSTOMER NAME: Alvin James Hansen Trust	CONTACT:
AGENT NAME: Karl Bundesen - Century 21 Real Estate	CONTACT: 707 769 9000
PROPERTY ADDRESS: 6195 Chileno Valley Rd, Petaluma Ca 94952	SENT TO: karl@bundesen.com

WELL DATA

LOCATION OF WELL:	Inside shed along driveway at base of hillside
TYPE OF WELL:	Drilled
DEPTH OF COMPLETED WELL:	Probe stopped at 35 Feet
DIAMETER OF WELL CASING:	8 -5/8" O.D. Steel
SANITARY WELL SEAL (PLATE SEAL AT OPENING OF WELL CASING):	Yes
ANNULAR SEAL (IN-GROUND SEAL OF BOREHOLE):	Unknown - Please Refer to well log
PUMP HP AND TYPE:	1/2 HP 230V Submersible
DEPTH OF PUMP SUCTION:	32.5 Feet

WATER PRODUCTION RESULTS

WATER LEVEL AT START (STATIC LEVEL):	7.7 Feet	FLOW RATE AT START:	19 GPM
FINAL PUMPING LEVEL:	32.5 Feet	FINAL FLOW RATE:	7 GPM
WATER LEVEL DRAWDOWN:	24.8 Feet	TOTAL LENGTH OF TEST:	4 Hours

CONSTANT PUMPING LEVEL INFORMATION

STABILIZED PUMPING LEVEL:	32.5 Feet	STABILIZED FLOW RATE (YIELD):	7 GPM
DURATION OF CONSTANT PUMPING LEVEL:	1 hour @ 7 GPM	TOTAL YIELD:	420 Gallons

WATER SYSTEM INSPECTION

WELL PUMP	Functional	TECHNICAL INFO: 13 GPM @ 60 PSI, control box dated 2005, 5.6 amps
ELECTRICAL	Functional	TECHNICAL INFO: 15 amp fuse disconnect
PRESSURE TANK	Deficient	TECHNICAL INFO: 44 Gallon WR 140, 0 PSI, Tank dated 1990
STORAGE TANK	See Comments	TECHNICAL INFO: 8000 Gallon Concrete
BOOSTER PUMP	None	TECHNICAL INFO:

WATER QUALITY TESTING

THE FOLLOWING SAMPLES ARE BEING ANALYZED. PLEASE REFER TO FOLLOW-UP REPORT FOR RESULTS.		
Homeowners panel 1	DATED: 9/24/12	TURNAROUND: Standard
	DATED:	TURNAROUND:
	DATED:	TURNAROUND:
	DATED:	TURNAROUND:

SEE NEXT PAGE FOR FURTHER INFORMATION...

DATE: 9/24/12

ADDRESS: 6195 Chileno Valley Rd, Petaluma Ca 94952

COMMENTS:
1. The recharge rate at the end of the test was 7 gallons per minute. This test may not represent the long term or seasonal yield. The water level recovered to 17 feet below surface 25 minutes after shutting off the pump.
2. The water was visibly clear at the start of the test, light yellow/brown for 2 hours and visibly clear the remainder.
3. The well pump and pressure tank fill the concrete storage tank on the hillside above the house. From the concrete tank, water gravity pressurizes the house. The pressure at the house measured 28 PSI.
4. The well is a shallow drilled well at the base of the hillside. It has a steel casing and it could not be confirmed that the well has an in-ground annular seal. It may be possible that during rains, the water may become discolored with silt/clay.
RECOMMENDATIONS:
1. The probe device meant to protect the well pump from dry running does not work. Recommend installing a pumpsaver 231 device.
2. The storage tank has a crack that is seeping water. The installation date is 1969. The tank has a wood roof that does not properly seal the opening of the tank. I recommend bypassing the tank and installing a modernized tank to serve as a better sealed method of water storage. Alternatively, this tank can just be used for agriculture and a smaller tank can be installed for the domestic supply.
3. The pipeline running up the hill to the tank has corroded couplings and is not buried completely. Recommend upgrading piping.
4. Water test results and treatment recommendations pending. It is recommended to use Ultraviolet treatment as a safeguard against bacteria when water is stored in a vented tank before it services the house.
5. The pressure switch is worn and should be replaced.
6. The pressure tank has a failed bladder and does not hold air pressure. Recommend replacing tank.
7. The wiring overhead and inside the pump shed is messy. The wiring in the pump house is not protected in conduit. Recommend electrical upgrades to prevent a hazard.
8. There is a hand dug well along the driveway. It does not have a pump in it. It measured 19 feet deep and the water level is 4 feet below surface. Recommend covering the well with a steel plate to prevent a hazard.

Thank you for allowing us to do your well inspection!

APPROVED BY: NICK BRASESCO



Water levels and well depth are measured as feet below top of well casing unless otherwise noted.

All wells and springs are subject to seasonal and yearly changes in regards to water yield, production and quality. Wells may be influenced by creeks or other water sources and are likely to yield less water during dry months of the year; typically August, September, & October. We make no predictions of future water production or water quality.

This report is for informational use only and is in lieu of and supercedes any other representation or statements of the agent or employee of the company, and all other such representations or statements shall be relied upon at the customer's own risk. The data and conclusions provided herein are based upon the best information available to the company using standard and accepted practices of the water well drilling industry. However, conditions in water wells are subject to dramatic changes in short periods of time. Therefore, the data and conclusions are valid only as of the date of the test and should not be relied upon to predict either the future quantity or quality the well will produce. The company makes no warranties either expressed or implied as to future water production and expressly disclaims and excludes any liability for consequential or incidental damages arising out of the breach of any expressed or implied warranty of future water production or out of any further use of the report by the customer.

Well head



Pressure tank




Storage tank




Hatch opening on tank



Float valve in storage tank



Overhead electrical



Fuse disconnect for well pump



Electrical into building



Hand dug well



Hand dug well

